NOTES FOR DESIGNER: (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)

- 1. WHEN EDITING DETAIL TO SUIT PROJECT, ADD JOB SPECIFIC REQUIREMENTS AND DELETE ONLY THOSE PORTIONS THAT DO NOT APPLY. TO SEEK A VARIANCE FROM APPLICABLE REQUIREMENTS, CONTACT THE ESM MECHANICAL POC.
- 2. SIZE CONDENSATE BRANCH LINE NO SMALLER THAN THE TRAP INLET. MINIMUM SIZE IS 3/4".
- 3. USE TWO PRV'S IN SERIES WHEN THE TOTAL REDUCTION IN PRESSURE IS MORE THAN A 10 TO 1 RATIO OF THE GAUGE PRESSURE. SEE SHEET 2. SET THE FIRST PRV AT APPROXIMATELY 60 PSIG AND THE SECOND AS REQUIRED.
- 4. USE TWO PRV'S IN PARALLEL WHEN THE LOAD DEMANDS FLUCTUATE THROUGH A WIDE RANGE. SEE SHEET 3.
- A. WHEN SPLIT BETWEEN LOADS IS UNKNOWN, SELECT VALVES WITH CAPACITIES OF 1/3 AND 2/3 OF THE MAXIMUM LOAD WITH THE SMALLER VALVE SET AT 2 PSIG HIGHER THAN THE LARGER VALVE. (AS THE LOAD INCREASES, THE PRESSURE DROPS AND THE LARGER VALVE OPENS).
- 5. RELIEF VALVE SETTINGS (PER 2000 ASHRAE SYSTEMS HANDBOOK, PAGE 10.10)
- NOTIFIED PRESSURE UNDER 35 PSI: SET RELIEF VALVE AT LEAST 5 PSI HIGHER THAN REDUCED PRESSURE.
- 6. BYPASS AROUND PRV SHALL BE EQUAL TO THE PIPING SIZE INTO PRV

REDUCED PRESSURE ABOVE 35 PSI: SET RELIEF VALVE AT LEAST 10 PSI HIGHER

THAN REDUCED PRESSURE

- 7. MOISTURE SEPARATOR SHALL BE LINE SIZE. INSTALL ONLY IN BUILDING STEAM SUPPLY LINE TO BUILDING.
- A. MINIMUM BUILDING SUPPLY LINE SIZE 2 1/2
- B. TRAP SIZE AND CONDENSATE PIPING SIZE SHALL BE THE SAME SIZE AS THE MOISTURE SEPARATOR DRAIN PORT. MINIMUM SIZE 3/4".

REFER TO THE FOLLOWING LANL STANDARDS FOR ADDITIONAL REQUIREMENTS:

œ

- SPEC 15121, STEAM AND CONDENSTATE SPECIALTIES (BLDG).
- SPEC 15181, STEAM AND CONDENSTATE PIPING (BLDG).
- SPEC 02554, STEAM AND CONDENSATE DISTRIBUTION (SITE)
- COMPLY WITH ASME B31.1 POWER PIPING. DESIGN STEAM PIPING FOR 150 PSIG AND 500 DEGREES F.
 DESIGN CONDENSATE PIPING FOR 250 DEGREES F.

9

 \circ \circ

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN IN-SERTED INTO A DRAWING PACK-AGE).

l															
PROJ	CLAS	•	7		DISCIF	SUBMITTED	BLDG X			_		ON	-	2	
CHAPTER 6	CLASSIFICATION: U	LOS Alam	J	Þ	DISCIPLINE POC: GURINDER GREWAL	ПЕО	×	STEAN		NGINEERIN	ADTS	DATE	8-13-03	1-4-06	
											1	CLASS REV	c	С	
ËR					GREWAL			DESI		S	臣	ADC		DY	
6 ST-D3020-2	REVIEWER: LARRY BAYS	P0 Box 1663 Los Alamos, New Mexico 87545	SHEET	STANDARDS MANAGER: TOBIN ORUCH	APPROVED FOR RELEASE	TA-X	STEAM PRV STATION DETAIL DESIGN NOTES		ENGINEERING STANDARDS MANAUL	ENGINEERING DIVISION	DESCRIPTION	REVISED NOTES. DWG NO. WAS ST6202.	REVISED TITLE BLOCK. ADDED NOTES FOR DESIGNER #9 AND REVISED #6.		
IJ		4		1	BIN O		DATE	CHEC	DESIGN	DRA	∐	DWN	꾸	광	
ا''ا	DATE:	OF.			RUCH		Ħ	Ě	Ž	2		NSSG	굒	ą	
$ldsymbol{ld}}}}}}$							6-2	CHECKED C.DuPRE	R.FROST	DRAWN R.PEARSON		DWN DSGN CHKD SUB APP	7K	ΑY	
N∄		4					6-28-99	"	-	NOS		ans	8	8	
نث			4									ş	₫	귱	